



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 282-05-E

Manufacturer: Winston Products Co., 2345 Carton Drive, Louisville, KY 40299

Trade Name(s): Winston

Product: Commercial electric food warmers (holding cabinets)

Pertinent Code Section(s): 27-787, 27-792

Prescribed Test(s): RS 14-6 (UL 197)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File E49804, dated May 5, 1994, revised July 5, 1995, UL File 49804, Sections 14, 13, 11.

Description: Commercial electric food warmers (holding cabinets). Units are comprised of heating elements, thermostats, pilot lights, on-off switches, limit controls and terminal blocks.

Product Covered:

Model Nos.	Description
HA-5503, -5507, -5508, -5509, -5511, -5519, -5522 HA-6503, -6507, -6508, -6509, -6511, -6519, -6522 HA-7503, -7507, -7508, -7609, -7511, -7519, -7522	Holding Cabinets
HE-6503, -6507, -6508, -6509, -6511, -6519, -6522 HE-7503, -7507, -7508, -7509, -7511, -7519, -7522	Holding Cabinets
HA-3022, -3522, -3003, -3503, -3007, -3507, -3009, HA-3509, -3011, -3511, -3519	Holding Cabinets

Model Nos.	Description
HA-4022, -4522, -4003, -4503, -4007, -4507, -4009, HA-4509, -4011, -4511, -4519	Holding Cabinets
CAC503, CAC509, CAC511, CAC522 CAT522, CAT529, CAT509	Cooking Cabinets
HBXXN1, HBX0N2, HBX0N3, HBXXD1, HBXXW1, HBXXD2, HBXXD3	Holding Drawers

Electrical Ratings/Model Differences:

Model No.	Ratings,60 Hz		
	V	A	W
HA5503	240	16.9	3800
HA5503	208	14.8	2850
HA5503	208	19.3	3800
HA5507	240	16.9	3800
HA5507	208	14.8	2850
HA5507	208	19.3	3800
HA5508	240	16.9	3800
HA5508	208	14.8	2850
HA5508	208	19.3	3800
HA5509	240	16.9	3800
HA5509	208	14.8	2850
HA5509	208	19.3	3800
HA5511	240	16.9	3800
HA5511	208	14.8	2850
HA5511	208	19.3	3800
HA5519	240	16.9	3800
HA5519	208	14.8	2850
HA5519	208	19.3	3800
HA5522	240	16.9	3800
HA5522	208	14.8	2850
HA5522	208	19.3	3800
HA6503	240	14.1	3120
HA6503	208	12.3	2340
HA6503	208	16.8	3264
HA6507	240	14.1	3120
HA6507	208	12.3	2340
HA6507	208	16.8	3264

Terms and Conditions: The above commercial electric food warmers are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical Code requirements.
2. Adequate supply of fresh air shall be provided into room or space enclosing equipment for unit ventilation and combustion requirements.
3. Satisfactory room exhaust system shall be furnished.
4. The installation shall not obstruct accessibility for operation and servicing.
5. Approval of all electrical equipment apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
7. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 3/21/07

Examined By [Signature]