

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner

MEA 283-00-E

Report of Material and Equipment Acceptance Division

**Manufacturer - System Sensor, A Division of Pittway, 3825 Ohio Avenue,
St. Charles, IL. 60174**

Trade Name(s) - System Sensor.

Product – Fire Alarm Equipment.

Pertinent Code Section(s) – Reference Standard RS 17-3, RS 4-6 (886-89-BCR).

Test(s) - UL 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL file S911, Project 00NK04635, Volume 54, Section 1, Issued May 3, 2000, and UL letter dated May 23, 2000.

Description - System Sensor's Smoke-Automatic Fire Detector Photoelectric as follows:

Model No.	Description
2112ATL	Smoke-Automatic Fire Detectors Photoelectric
2112TL	Smoke-Automatic Fire Detectors Photoelectric

The Models 2112ATL and 2112TL are very similar 4-wire smoke detectors with integral heat detectors except that the 2112ATL has added circuitry and components for a built-in audible signal. The audible signal is control panel activated.

Ratings:

Detector	Base	Normal standby		Alarm	
		Voltage, V dc	Current, mA	Voltage, V dc	Current, mA
2112TL	A10-26-XX	9.5 - 14.0	-	12	13
2112ATL	A10-26-XX	9.5 - 15	3	12	20