



NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 283-01-M Vol. 2

**Manufacturer:** ThyssenKrupp Elevator, 1125 Schilling Boulevard East, Collierville, Tennessee 38017

**Trade Name(s):** ThyssenKrupp

**Product:** Passenger Elevator Entry Fire Door

**Pertinent Code Section(s):** 27-342

**Prescribed Test(s):** RS5-6 (ASTM E152)

**Laboratory:** Intertek Testing Services

**Test Report(s):** ITS Report No. J20029748.1, dated December 18, 2000, J200036543-231, dated February 8, 2001 and J20047784-231, dated May 29, 2001. ITS Report No. 3007967, dated September 28, 2001, ITS Report No. 3051129.03, dated January 16, 2004, ITS Report No. 3060357, dated June 21, 2004

**Description** – Passenger Elevator Door (16, 18 gauge steel) flush and extended (raised) panel design for installation in horizontal side and center opening 1 ½ hour locations (Model 148311S and Model 148311P) and 2 hour locations (Model 3502AD, Model 3502AV, and Model 3502BA).

**Limitations-** Maximum 4 panels per opening. Maximum 3 15/16" thick for extended (raised) panel design.

<b>Model</b>	<b>148311P</b>	<b>148311S</b>	<b>3502AD</b>	<b>3502AV</b>	<b>3502BA</b>
<b>Maximum Width</b>	<b>43 ½ inch</b>				
<b>Maximum Height</b>	<b>108 ½ inch</b>	<b>96 ½</b>	<b>114 ½ inch</b>	<b>114 ½ inch</b>	<b>114/ ½ inch</b>
<b>Thickness</b>	<b>1 ¼ inch</b>	<b>1 ¼ inch</b>	<b>2 7/8 INCH</b>	<b>2 7/8 inch</b>	<b>2 3/4 inch</b>
<b>Thickness, extended panel</b>	<b>3 15/16 inch</b>				

**Terms and Conditions:** That the above described door assemblies be accepted as having 1-1/2 hour fire protection rating when installed in accordance with RS 5-8 and RS 18-1 and when provided with an MEA accepted interlock assembly on condition that the certificates or labels accompanying all shipment be provided by the testing laboratory which shall be regularly engaged by the manufacturer to make periodic inspections and/or tests of the doors in the course of their manufacture.

All shipments and deliveries of such materials are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance May 31, 2006  
 Examined by Sam Deshpande