



**Report of Materials and  
Equipment Acceptance Division**

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

**MEA 286-06-M**

**Manufacturer:** COOLEY INCORPORATED, 50 ESTEN AVENUE, PAWTUCKET, RHODE ISLAND, 02862

**Trade Name(s):** PREMIUM KNIT MESH (PKM) 2947, 1895, 1083

**Product:** PVC COATED FABRIC FOR FLEXSIGN

**Pertinent Code Section(s):** 27-449, 27-506, 27-507, AND TPPN# 11-99

**Prescribed Test(s):** RS-73 {NPFA701 (TEST METHOD 2)}

**Laboratory:** MAGILL LABORATORIES

**Test Report(s):** REPORT #0289, DATED MARCH 14, 2006

**Description** – Premium knit mesh is an 8oz. flame retardant PVC coated knit polyester fabric. The base fabric is 3oz. polyester. The PVC total weigh is 5 oz. The intended application is for banners and billboards.

**Terms and Conditions:** That the above material is accepted as meeting the flame resistance requirements of Section 270596 and 27-507 of the Building Code, for use on flex signs. The acceptance of this material is limited to flame resistance only. Structural and other requirements shall be in accordance with pertinent Building Code provisions and Technical Policy and Procedure Notice #11/99. All installations, uses and locations shall be in accordance with the New York City Building Code, specifically Section 27-499 and 27-501, and the Zoning Resolution. All shipments and deliveries of such materials shall, in addition, be accompanied by a metal tag certifying that the materials shipped or delivered are equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance July 6, 2006

Examined By Sun Derkhdan

