



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 287-06-E

Manufacturer: American Dryer Corporation, 88 Currant Road, Fall River, Massachusetts 02720

Trade Name(s): American Dryer Corporation, ADC, Continental Girbau, Maytag, Pellerin Milnor

Product: Commercial/Domestic natural gas clothes dryers

Pertinent Code Section(s): 27-800, 27-807, RS 14-2 (ANSI Z223.1)

Prescribed Test(s): RS 14-6 (ANZI Z21.5)

Laboratory: CSA International

Test Report(s): 168704-1602753, 168704-1734421, 168704-1662731, 168704-1694322, 168704-1673672

Model No.	Report Nos.	Dated	Drum Capacity Pounds	Nominal Input Rating BTUH
SLGH20(B,T), CGS2025(B,T)	168704-1602753	3/22/05	20#	40,000
SLGH2020			40# (20# per pocket)	80,000
SLGH2929	168704-1734421	12/19/05	60# (30#) per pocket	100,000
SLGH31(B,T), CGS3040 (B,T),M31SLG(C) MDG 31	168704-1662731	6/21/05	30#	55,000
SLGH3131, CGS3131G, M3131SLG(C), MLG33			60# (30# per pocket)	110,000
SLGH50, CGS5060G, M50SLG(C) MDG 51	168704-1694322	8/17/05	50#	90,000
SLGH75, CGS7585, M75SLG(C), MDG 77	168704-1673672	7/27/05	75#	110,000

Terms and Conditions: That the above described commercial gas fired clothes dryer be accepted for use when fired by natural gas only. Provision for combustion air and ventilation air shall be made in accordance with Section 27-807 and other applicable Code requirements. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Building before installation.

Notes: Units maybe installed on combustible flooring. Minimum installed clearances from combustible construction shall be in accordance with RS 14-15 of the Building Code.

Final Acceptance July 12, 2006

Examined by Siun Derphudam