



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 29-05-E

Manufacturer: Heat Wagon Inc., 342 N. Country Road, 400E Valpariso, Indiana 46383.

Trade Name(s): Heat Wagon.

Product: Combination gas/oil heaters.

Pertinent Code Section(s): 27-800, 27-826, 27-831.

Prescribed Test(s): RS 14-6 (UL 733), RS 14-6 (ANSI Z83.7).

Laboratory: CSA International.

Test Report(s): No. 189672-1110831, dated July 31, 2000; 189672-1374886 dated February 14, 2003.

Description – The products covered by this report are gas, oil, or combination gas/oil fired construction heaters for indoor and outdoor applications. Units, with model numbers and ratings are listed below:

Commercial Heaters (GA) Direct Construction Heaters	
Model No.	Maximum Input BTUH
VG400	400,000
VG400	360,000
VG-1000	1,000,000
VG-1000	900,000
Natural Gas Indirect Fire Heaters	
VG400	
VG1000	
Oil/Indirect Fired Heaters	
VF-400	400,000
VF-400	360,000
VF-1000	1,000,000
VF-1000	900,000

Construction Heaters	
1800	750,000
1801	750,000
2000	1,000,000
2730	2,000,000
3050	3,500,000

Note: Minimum installed clearances from combustible construction shall be accordance with RS 14-15 of the New York City Building Code.

Terms and Conditions: The above described air heaters, be accepted for commercial and industrial installation only, when fired by fuel oil No. 2 or natural gas only, when installed in accordance with clearances to combustible construction cited above, under the following conditions:

1. If heaters are installed in combination with cooling system, then heating/cooling system shall be MEA accepted.
2. Provisions for combustible air and ventilation air shall be made in accordance with Section 27-131, and other applicable code requirements.
3. All shipments and deliveries of such equipment shall be accompanied by a certificate or label certifying that the equipment shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department before installation.

Final Acceptance September 29, 2005

Examined by Shyam Prasad SD