



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 295-07-M

Manufacturer: Diversified Foam Products, Inc.
5117 Central Highway
Pennsauken, N.J. 08109

Trade Name(s): The FloorMuffler

Product: Flooring underlayment
MEA Index #340-50 – Floor Underlayment

Pertinent Code Section(s): 27-351, 27-348

Prescribed Test(s): RS 5-5 (ASTM E84, ASTM E90-02, ASTM E462-90,
ASTM E989-89)

Laboratory: NGC Testing Services

Test Report(s): FH-1730 dated April 18, 2007
NGC 7004005 dated February 26, 2004
NGC 5004002 dated February 26, 2004

Description: The FloorMuffler® is a high performance acoustical floor underlayment developed to address both reflective and through-the-floor sound for laminate, engineered and hardwood floors. The FloorMuffler® is also designed with a moisture barrier system, so no additional film is required.

Flame Spread Rating: 15
Smoke Developed Rating: 95

Terms and Conditions: The above-described material is accepted for use as underlayment for finish flooring under the following conditions:

1. The material may be used when a Class "A" flame-spread rating is required.
2. The material shall be used in accordance with the New York City Building Code.
3. All shipments and deliveries of such material shall be provided with a label, suitably placed, certifying that the material shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance February 13, 2008
Examined By Sam Desfleur