



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 297-05-E

Manufacturer: Spring Air Systems Inc. 1464 Cornwall Road, Unit 6
Oakville, ON L6J-WS

Trade Name(s):

Product: Commercial Kitchen Exhaust Hoods with exhaust
damper

Pertinent Code Section(s): 27-777

Prescribed Test(s): RS 13-3 (UL 710).

Laboratory: Underwriter's Laboratories Inc.

Test Report(s): File MH 26919 (CR 1907) dated July 2, 2003. E.P.
Index No# 051100413.

Description – Exhaust hoods with exhaust dampers for restaurants-type cooking:

Models: FD, DD, CD, CF, CT, HD, HF, and HT. Hood lengths range from 0.9 m – 4.725 m (3 feet to 15.6 feet).

USL, CNL – Exhaust hoods without exhaust dampers for restaurants – type cooking:

Models: FN and DN. Hood lengths range 0.9 m – 4.725 m (3 feet to 15.6 feet).

Terms and Conditions: That the above described commercial kitchen exhaust hoods, when installed in accordance with the installation instructions supplied by the manufacturer and reference Standard RS 13-3, be accepted as conforming to code requirements for exhaust hoods. Installation of grease filters and grease extraction devices shall be as prescribed by the Code and shall be accepted by this Division. All shipments and deliveries of such exhaust hoods shall be provided with a permanent die stamped identification on the units themselves certifying that the exhaust hoods shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 5/24/06
Examined by Shyam. P. Nene