



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Robert D. LiMandri, Acting Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 297-06-E

**Manufacturer:** Lennox Industries, Inc.,  
200 S. 12<sup>th</sup> Ave.  
Marshalltown, IA 50158

**Trade Name(s):** Dave Lennox Signature Collection

**Product:** Packaged air-conditioner/condensing units  
MEA Index #20-20 – Air Conditioning Equipment

**Pertinent Code Section(s):** 27-770, 27-777

**Prescribed Test(s):** RS 13-11A (UL 1995)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** File SA11694, Project 04RT08183 dated  
January 26, 2005.

**Description:** Condensing units as described below:

Model Designation	Capacity Rating – Tons
XC21-024-230	2
XC21-036-230	3
XC21-048-230	4
XC21-060-230	5

**Terms and Conditions:** The above described condensing units are accepted under the following conditions:

1. Units shall use only refrigerant R-410A.
2. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 5/22/2008.

Examined By Bashir Shalke