

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

MEA 298-03-E  
Report of Material and Equipment Acceptance Division

Manufacturer – Hearth & Home Technologies Inc., 20802 Kentington Boulevard,  
Lakeville, MN 55044.

Trade Name – Hearth & Home Technologies.

Product – Gas fired vented decorative fireplace appliance.

Pertinent Code Section(s) – 27-800, RS 14-2 (ANSI Z223).

Prescribed Test(s) - RS 14-6 (ANSI Z21.50-1982, Z21.88).

Laboratory – Underwriters Laboratories Inc.

Test Report(s) – UL File MH26108 dated March 19, 2003; MH15519 dated August 7,  
1995 revised April 1, 2003; dated April 23, 1999; September 19, 2000, and  
September 20, 2000.

Description – Gas fired decorative fireplace appliance designed to provide  
supplemental heating and to enhance the aesthetics of a room. All of the  
below units are equipped with electric ignition.

Model	Rating (BTU/hr) (NG only)	Description
GCBC60	22,000-32,000	Up-Vent Decorative Gas Appliance
GCBC80	23,000-35,000	Up-Vent Decorative Gas Appliance
GDCH60	24,000-34,000	Direct Vent Decorative Gas Appliance
GDCL60	24,000-34,000	Direct Vent Decorative Gas Appliance
GDCR60	24,000-34,000	Direct Vent Decorative Gas Appliance
GDFL60	24,000-34,000	Direct Vent Decorative Gas Appliance
GDST60	24,000-34,000	Direct Vent Decorative Gas Appliance
GGBR60	34,000	Up-Vent Decorative Gas Appliance
GGBR80	36,000	Up-Vent Decorative Gas Appliance
GNTC50	21,000/15,000	Direct Vent Decorative Gas Appliance
GNTC80	29,000/20,000	Direct Vent Decorative Gas Appliance
IB75	50,000	Up-Vent Decorative Gas Appliance
CALIBER NXT70	40000/28,000	Direct Vent Decorative Gas Appliance
CALIBER NXT90	45000/29,000	Direct Vent Decorative Gas Appliance
Novus NB3630	20,000/14,000	B-Vent Gas Appliance
Novus NB3933	22,000/15,000	B-Vent Gas Appliance
Novus NB4236	25,000/17,000	B-Vent Gas Appliance
Novus NB4842	30,000/20,500	B-Vent Gas Appliance
Novus ND3630	20,000/14,000	Direct Vent Gas Appliance
Novus ND3933	22,000/15,000	Direct Vent Gas Appliance
Novus ND4236	25,000/17,000	Direct Vent Gas Appliance
Novus ND4842	30,000/20,500	Direct Vent Gas Appliance
Dakota	61,000	Outdoor Gas Appliance
Infinity	35,000	Vented Gas Fireplace
BVBC36	23,000	B-Vent Gas Appliance
ADI-ZC-FB	29,650	Vented Gas Fireplace Heater
QV-25FB	29,650	Vented Gas Fireplace Heater
FB-ZC	29,650	Vented Gas Fireplace Heater

Recommendation - That the above described gas fired vented appliance, be accepted for decorative heating operation on natural gas only, with combustion air and required ventilation air provided. Venting of the fireplace is subject to Section 27-879 of the Building Code. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance Jaya M. [Signature]

Examined By 9/25/03