

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 299-02-E

Report of Material and Equipment Acceptance Division

Manufacturer – Fire-Lite Alarms, One Fire-Lite Place, CT 06472-1001.

Trade Name(s) – Fire-Lite.

Product – Fire Alarm Equipment.

Pertinent Code Section(s) – 27-968 through 27-977, RS 17-5, ANSI, NFPA 72.

Test(s) – RS 17-5, ANSI, NFPA 72, UL 864, UL 1481.

Laboratory – Underwriters Laboratories Inc.

Test Report(s) – UL File S2424, Vol. 11, Sec. 2, issued May 31, 2002. UL ML File S635 issued June 21, 2002.

Description – The FCPS-24FS6 and FCPS-24FS8 are remote power supply/battery chargers. The FCPS-24FS8 is capable of eight amps and the FCPS-24FS6 is capable of six amps of power. The FCPS-24S6 and FCPS-24S8 are multiple listed for Notifier.

Pursuant to “Promulgation of the Rules relating to Material and Equipment Application Procedures” dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated September 23, 2002, F.P. Index 0209018.

Recommendation - That the above units be accepted on condition that all uses, configurations arrangements, functions, applications, and installations shall comply with Article 17, Reference Standard RS-17 of the New York City Building Code, the Electrical Code of the City of New York, applicable Fire Prevention Directives, and the manufacturer’s instructions.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance FEBRUARY 13, 2003

Examined by Donald [Signature]