

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 3-03-E

Report of Material and Equipment Acceptance Division

Manufacturer—System Sensor, 3825 Ohio Avenue, St. Charles, Illinois 60174.

Trade Name – Honeywell.

Product – Fire Alarm Equipment.

Pertinent Code Section(s) – Reference Standard RS 17-3, RS 4-6 (886-89-BCR).

Tests – UL 864.

Laboratory – Underwriters Laboratories, Inc.

Test Reports – UL file S3705 Volume 3, Section 1, issued October 28, 1987, revised January 30, 2002.

Description – These units are intended for use with this manufacturer's Model Deltanet Fire and Security System. The devices are intended to be interconnected on the intelligent communication circuit provided by the control unit.

These modules consist of a small plastic enclosure providing field-wiring terminals, which is mounted to a metal mounting bracket. This assembly is intended to be mounted in a standard 4-in. square junction box. The overall assembly is provided with a plastic faceplate to be surface mounted after installation.

Model Number	Description
TC811A1006	Fault Isolator
TC809D1004	Dual Monitor

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated January 8, 2003, F.P. Index 0301002.

Recommendation - That the above equipment be accepted provided that all uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Buildings Codes, specifically Subchapter 17, and Reference Standard 17-3. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72, and UL Standard.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

April 25, 2003

Examined by

