



NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 3-99-E Vol. 2

Manufacturer: Signal Communications Corporation, 4 Wheeling Avenue, Woburn, MA 01801

Trade Name(s): Kidde-Fenwal®

Product: Fire alarm pull stations

Pertinent Code Section(s): RS 17-3, 3A, 3B; RS 17-5 and Subchapter 17

Test(s): UL 38

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL Multiple Listing Correlation sheet, File No. S1778, issued September 4, 1996 and revised October 13, 2006

Description: Fire alarm pull stations by Kidde-Fenwal, Inc. The corporation requests to multiple-list the UL-listed model numbers 30-330001-001, -002 and 84-330001-001, -002 with Signal Communications Corporation MEA-approved model numbers as follows:

Basically listed Signal Communications Corp. Models	Component Description	Multiple-listed Kidde-Fenwal, Inc. Models
SG-42SK1	Boxes, non-coded	30-330001-001
SG-42CXK1	Boxes, non-coded	30-330001-002
SG-44SK1	Boxes, non-coded	84-330001-001
SG-44CXK1	Boxes, non-coded	84-330001-002

Terms and Conditions: The above units are accepted, provided that:

1. All uses, configurations, arrangements, functions, application and installations comply with all applicable provisions of New York City Building Code, specifically Subchapter 17, and Reference Standards RS 17-3.
2. The installation and use shall be in accordance with the manufacturer's recommendations, NFPA-72 and UL standard.
3. Only those models painted red shall be permitted.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance May 22, 2007
Examined By Donald [Signature]