



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 30-08-E

Manufacturer: Honeywell International Inc.
12 Clintonville Road
Northford, CT 06472

Trade Name(s): Notifier

Product: Addressable charger/power supplies

Pertinent Code Section(s): Subchapter 17 & Reference Standard RS 17

Prescribed Test(s): UL 864, 9th Edition

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File S635, Project 06NK20946 issued April 6, 2007.

Description: The Notifier models, **ACPS-610** and **ACPS-610E**, are auxiliary power supplies with a battery charging option. Selectable outputs provide 6 amps of power to four Notification Appliance Circuit (NAC) outputs while charging batteries fro 12 to 200 AH, or 10 amps of general purpose power when configured as an external battery charger. These models are compatible with MEA-approved Notifier intelligent fire alarm control panels using the Classic Loop Interface Protocol (CLIP) or FlashScan® protocol.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections (letter dated February 28, 2008, F.P. Index #0802033).

Terms and Conditions: The above models are accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations shall comply with the provisions of the New York City Building, specifically Subchapter 17 and Reference Standards RS 17-3, 17-3A, 17-3B, 17-3C and 17-5. Further, the installation shall be in accordance with the manufacturer's recommendations and UL Standard.
2. The above-described models shall be used only with listed, approved or accepted equipment and accessories with which the compatibility has been determined by the Engineer of Record or the UL test report.
3. Underwriters Laboratories, Inc.'s listing requirement and limitations shall be complied with.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance March 20, 2008.
Examined By Donnell J. J.