



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 31-05-M (Corrected)

(This Publication supersedes in its entirety the Publication of November 29, 2007)

Manufacturer: ProTech Systems Inc.
400 South Pearl Street
Albany, N.Y. 12202

Trade Name(s): FasNSeal

Product: Chimney liner/double wall (W2) special Gas vent system
MEA Index #130-10 – Chimneys

Pertinent Code Section(s): 27-869.03(b)

Prescribed Test(s): NFPA 54, NFPA 211, ASHAE 30.

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File MH25700 dated July 17, 2002.

Description: This special gas vent system is intended to be connected directly to the flue outlet of Category III and IV gas burning appliances, as defined by the National Flue Gas Code, ANSI Z223.1 NFPA 54. The vent is intended to be installed in accordance with requirements contained in the Standard for Chimney, Fireplaces, Vents and Solid Fuel Burning Appliances, NFPA 211.

This special gas vent system consists of a stainless steel inner wall with a stainless steel outer wall. The annular space between the inner and outer walls is 0.50 inch.

Product Covered:

Model: FasNSeal W2 – Special gas vent system.

Terms and Conditions: The above-described chimney lining system is accepted with the following conditions:

1. All installations shall be in accordance with the New York City Building Code, and the manufacturer's and listing laboratory's instructions and recommendations.
2. All shipments and deliveries of such materials shall be provided with a label, suitably placed, certifying that the materials shipped or delivered are equivalent to those tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance July 23, 2008

Examined By Sam DePhelan