



NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 31-07-E

Manufacturer: Euroflues, LLC, 1813 Hopi Road, Santa Fe, NM 87506

Trade Name(s): Focus/Euroflues

Product: Factory-built fireplaces (solid fuel)

Pertinent Code Section(s): 27-848

Prescribed Test(s): RS 14-21 (UL 1482), RS 15-15 (UL 127 modified)

Laboratory: OMNI Test Lab

Test Report(s): 304-F-04-2 dated 7/29/2005; 304-F-12-2 dated 10/5/2005; 304-F-06-2 dated 9/29/2005; 304-F-08-2 dated 12/1/2005; 304-F-01-2 dated 5/20/2005; 304-F-13-2 dated 11/23/2005, 304-F-09-2 dated 10/6/2005 and 304-F-05-2 dated November 23, 2005.

Description: Free-standing, solid fuel stoves for residential heating. Models with description and one-hour output for each appliance are listed below:

Model Name	BTUH	Model Name	BTUH
Ergofocus	24,373	Bathyscafocous	24373
Iotafocus	20,629	Stellafocus	32,011
Agorafocus 630	25,771	Chromifocus	32,011
Emifocus	14,938	Unifocus	32,011
Edofocus 630	16,935	Omegafocus	32,011
Paxfocus	16,935	Octofocus	32,011
Eurofocus 950	12,093	Metafocus	32,011
Eurofocus 1200	12,093	Filiofocus	25,272
Mejifocus	21,278	Ifocus	17,784
Pictofocus 1200	30,663	Pictofocus 1450	30,663

Terms and Conditions: The above-described factory-built fireplaces are accepted for use as supplemental heating and decorative purposes under the following conditions:

1. The installation shall be in accordance with manufacturer-supplied instructions and Section 27-848 of the New York City Building Code. Furthermore, units shall be vented in accordance with Section 27-856 of the Building Code.
2. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
3. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 6/4/07

Examined By Shepherd. [Signature]