



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 314-06-E

Manufacturer: HiSEER International Fangcun/Foshan Branch
238 Huadi Road
Fangcun, Guangdong CHINA 510370

Trade Name(s): HiSEER

Product: Room air-conditioning system
MEA Index #20 – Air Conditioning Equipment

Pertinent Code Section(s): 27-770, 27-777, 27-800, RS 15-1 (ANSI Z223.1)

Prescribed Test(s): RS 13-11B (ANSI B9.1), RS 13-11 (UL 1995)
RS 14-6 (ANSI Z21.47)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File SA12793, dated May 2, 2003 and revised
January 30, 2004.

Description: This is a cord-connected, portable type room air conditioner. Unit operation is provided by solid state controls. Control modes include cooling, fan only, and dehumidify. Three fan speeds may be selected for each of the cooling, and fan only modes. While in dehumidify mode, the non-adjustable fan speed is reduced to a slow speed setting. The swing motor may be turned on and off in all modes. A removable condenser air discharge tube is provided with the unit to move heated air away from the conditioned space.

Product Covered:

Portable type room air conditioner - Models: KY-22/b, KY-25/b

Models: KYD-22/b, KYD-25/b

Terms and Conditions: The above-described room air-conditioning units are accepted under the following conditions:

1. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770 as to maximum sound levels permitted for exterior mechanical equipment.
2. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
3. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance March 13, 2008

Examined By Shyam Prasad
SD