



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 315-06-E

Manufacturer: LG Electronics Inc.
Air Conditioners OBU
76 Seongsan-dong, Changwon-SHI
Kyoungsangnam-DO, 641-310, KOREA

Trade Name(s): LG

Product: Packaged terminal air conditioners/heat pumps

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-6 (ANSI B9.1), RS 13-11 (UL 1995)

Laboratory: UL Korea LTD

Test Report(s): SA13362, issued March 17, 2006.

Description: Packaged, terminal air-conditioning and heat pump units, as stated below:

Model No.	Description	Unit Type (Indoor/Outdoor/Both)	Cooling/Heating Capacities (BTUH)
LP120CED LP150CED LP090CED	Packaged Terminal Air Conditioners	Single Units	11,800/11,500 14,300/14,100 9,000/8,800
LP120HED LP090HED	Packaged Terminal Heat Pumps	Single Units	12,100/11,800 9,100/8,900

Terms and Conditions: The above-described units are accepted under the following conditions:

1. Units shall use Refrigerant R-22 only.
2. If utilized for residence heating, the circulatory air system shall have (a) one register or grille without a damper, or (b) dampers and shutters within the system shall be constructed or controlled so long as to prevent closure beyond 80 percent of the gross duct area at all times.
3. Such equipment shall meet the requirements of Section 27-131, noise control of mechanical equipment, subdivision 4, as to maximum sound levels permitted, when located within 100 feet of any dwelling unit window.
4. A tag must be permanently affixed to the equipment stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770 as to maximum sound levels permitted for exterior mechanical equipment.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
7. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 11/28/07
Examined by [Signature]