



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 315-07-E

Manufacturer: Lennox Hearth Products
1110 West Taft Avenue
Orange, CA 92865

Trade Name(s): Lennox

Product: Gas-fired fireplaces
MEA Index #300 – Fire Place

Pertinent Code Section(s): 27-800, RS 14-2 (ANSI Z223)

Prescribed Test(s): CAN/FGA 2.17-M91

Laboratory: Intertek

Test Report(s): 14457 issued December 4, 2007

Description: Gas-fired, gravity and fan-type vented wall furnaces designed to be built into surrounding construction. Units are equipped and operated with a piezo/standing pilot ignition system and an electric ignition system. Unit front contains operable glass doors for viewing the flame and simulated wood logs.

Product Covered:

Model No.	Input Rating (Btu/Hr)
LMBV-36	24,000
LMBV-42	30,000

Terms and Conditions: The above-described appliances are accepted for decorative heating under the following conditions:

1. Units shall be fired with natural gas only.
2. Units are for indoor installation only with combustible air and required ventilation air provided.
3. Venting of the equipment is subject to Section 27-879 of the New York City Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 2/20/08

Examined By Shymon