



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 317-01-E Vol. 10

Manufacturer: Notifier, 12 Clintonville Road, Northford, CT 06472-1001

Trade Name(s): Notifier

Product: Fire alarm equipment

Pertinent Code Section(s): 27-968 thru 27-977, RS 17

Test(s): UL Standard 864

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL Category SYZV (Releasing) page for NFS-640 from UL website.

Description: Fire protection equipment.

Product Description	Notifier
Fire Alarm Control Unit	NFS-640
CPU Module	CPU-640
Network Control Annunciator	NCA
Annunciator Keyswitch	AKS-IB
Annunciator Flush Boxes	ABF-IB/-IDB/-2B/-2DB/-4B
Annunciator Backboxes	ABS-IB/-I TB/-2B/-4D
CAB Series (Doors)	DR-A4(+)/-B4(+)/-C4(+)/-D4(+)

Note: The NFS-640 fire alarm control unit also has the releasing capability.

Terms and Conditions: The above units are accepted on condition that:

1. All uses, configurations, arrangements functions, application and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standards 17-3, 17-3A, 17-3B, 17-3C and 17-5. Further, the installation shall be in accordance with the manufacturer's recommendation and UL standard.
2. When used with central office communicator or a transmitter, the installation and operation of the control unit equipment and devices shall comply with 3RCNY § 17-01. It shall have the capability of transmitting separate and distinct signals to indicate manual pull station alarm, automatic detection alarm, sprinkler waterflow alarm, supervisory signal indications and trouble indications.
3. The connection of security/burglar devices and equipment to the fire alarm control unit is prohibited. A sign must be provided to indicate same.
4. Installation of pre-recorded evacuation messages in the fire alarm control unit shall require a prior approval from the Department.
5. All enclosing cases for fire alarm equipment shall be painted red in accordance with the requirements of Reference Standard 17-3(7).
6. When the above referenced control unit is employed for CO₂ releasing applications, the following shall be complied with:
 - a. All safety precautions stated in NFPA 12 shall be strictly followed.
 - b. Provide signs at every entrance to protected space to read as follows:

“WARNING: DO NOT ENTER THE PROTECTED PREMISE SPACE UNLESS PHYSICAL LOCKOUT OR OTHER SAFETY PROCEDURES ARE FULLY COMPLETED. DO NOT USE SOFTWARE DISABLE FUNCTIONS IN THE PANEL AS LOCKOUT.”
7. The above referenced fire alarm equipment shall be used only with listed and approved accessories with which the compatibility has been determined by the Engineer of Record or a UL test report.
8. All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the New York City Building Code.

Final Acceptance

Examined By

May 17, 2007.
Donald [Signature]