



NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 317-01-E-4 (Correction)

Note: This publication reflects revisions to Terms & Conditions (Recommendation) item #1, as per Fire Department correspondence dated September 9, 2005.

Manufacturer: Notifier, 12 Clintonville Road, Northford, CT 06472-1001.

Trade Name(s): Honeywell.

Product: Fire Alarm Equipment.

Pertinent Code Section(s): 27-968 thru 27-977, Reference Standard RS 17-5 ANSI/NFiPA/No. 72.

Test(s): RS 17-5 ANSI/NiPA No. 72; UL 864.

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL Multiple Listing Files (S470)

ML File	Date(s)	Description
S470	Issued February 12, 2003	(XLS140, XLS140-CPU)
S470	Issued March 31, 2003	(XLS-LCD-80)
S470	Issued February 12, 2003	(XLS-LBB/-LBBR)
S470	Issued February 12, 2003	(XLS-NCA, XLS-AKS-1B)
S470	Issued February 12, 2003, revised February 13, 2003	(XLS140-DR-A4/-A4R/-B4/-B4R/- C4/-C4R/-D4/-D4R)
S470	Issued February 12, 2003, revised February 13, 2003	(ABS-1TB/-4D/-4DR, ABF-1B/-2B/- 4B/-1DB/-2DB)

Description – The Honeywell International, Inc.'s Model XLS-140 fire alarm control station is multiple listed with Notifier's Model NFS-640 (317-01-E). It is an intelligent addressable fire alarm system and has one signaling line circuit (SLC), expandable to two. It also has releasing capability.

Description	Honeywell	Notifier
CPU Module	XLS140-CPU	CPU-640
LCD Annunciator	XLS-LCD-80	LCD-80
Battery Backbox, Black Color	XLS140-LBB	NFS-LBB

Battery Backbox, Red Color	XLS140-LBBR	NFS-LBBR
Network Control Annunciator	XLS140-NCA	NCA
Control Panel Doors	XLS140-DR-A4/-A4R/-B4/-B4R/-C4/-C4R/-D4/-D4R	DR-A4/-A4R/-B4/-B4R/-C4/-C4R/-D4/-D4R)
Annunciator Backboxes	XLS140-ABS-1TB/-ABS-4D/ABS-4DR,ABF-1B/-2B/-4B/-1DB/-2DB)	ABS-1TB/-4D/-4DR, ABF-1B/-2B/-4B/-1DB/-2DB)
Annunciator Key Switch	XLS-AKS-1B	AKS-1B

The Honeywell XLS-140 Intelligent addressable fire alarm system uses the same optional equipment as the NFS-640 including only compatible Honeywell MEA listed manual pull stations, Honeywell detectors and modules.

Terms and Conditions: That the above units be accepted on condition that all uses, configurations, arrangements and functions, applications and installations shall comply with the provisions of the New York City Building Code, specifically Subchapter 17 and Reference Standard RS 17-3, the UL Listing, and on further condition that:

1. Fire Alarm Control Unit, Honeywell XLS140:

When used with a central office communicator or a transmitter, the installation and operation of the equipment and devices shall comply with 3RCNY #17-01. It shall have the capability of transmitting separate and distinct signals to indicate manual pull station alarm, automatic detection alarm, sprinkler waterflow alarm, supervisory signal indications and trouble indications.

Prior to the installation of the pre-recorded automatic evacuation system, a specific approval for a specific installation must be obtained from the Fire Department.

The location of Fireman's Phone Jacks, method of installation and their performance must meet the provisions of #27-974 and #27-972(l)(2) of the Buildings Code.

The connection of security/burglar devices and equipment to a fire command station is prohibited. A sign must be provided to indicate the same.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in section 27-131 of the Building Code.

Final Acceptance June 27, 2006
 Examined by Donald [Signature]