



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 317-05-E

Manufacturer: Lennox Hearth products, 1110 Nest Taft Avenue, Orange, CA 92865

Trade Name(s): Signature

Product: Gas fired vented decorative fireplace appliance

Pertinent Code Section(s): 27-800, RS 14-2 (ANSI Z223).

Prescribed Test(s): RS 14-6 (ANSI Z21.50, Z21.88a, Z21.11, Z21.44).

Laboratory: OTL

Test Report(s): Certificate 11L-F-22-5 dated March 15, 2005

Description – Gas fired decorative fireplace appliance designed to provide supplemental heating and to enhance the aesthetics of a room.

Model Number	Maximum Input Rate	Minimum Input Rate
LSM4 0MN, LSM4 0EN	50,000	40,000
LSM4 5MN, LSM4 5EN	60,000	47,000
LSM4 0MN-2, LSM4 0EN-2	50,000	40,000
LSM4 5MN-2, LSM4 5EN-2	60,000	47,000

Model Number Breakdown

Basic Model:

LSM40

51" W x 38" H x 27" D

LSM45

57" W x 43" H x 30" D

Prefix:

**LS
M**

**Lennox Signature
Montebello**

Suffix:

**E
N, P
-2**

**Millivolt ignition
Electronic Ignition
Revised Burner/logs; higher LSM45P rate**

Clearances to Combustibles

	Inches	Millimeters
Back / Side (s)	0	0
Top	0	0
Vent/ Intake Top	3"	77
Vent/ Intake Sides	1"	26
Front ¹	13	331
Perpendicular Walls	36	915
Floor	0	0
Ceiling	64	
Mantle ²	9	

¹ Top of face plate to bottom of 8" wide mantle.

² 8" Wide Mantle.

See instructions for other mantle widths.

Terms and Conditions: That the above described gas-fired vented appliances, be accepted for decorative heating operation on natural gas only, for indoor installation only with combustible air and required ventilation air provided. Venting of the above equipment is subject to Section 27-879 of the Building Code. Approval of all electrical equipment, apparatus, materials, and devices, shall be obtained from the Department before installation.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance 6/27/06
Examined By Shyam M. Prasad