

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 319-02-E

Report of Material and Equipment Acceptance Division

Manufacturer – System Sensor, A Division of Pittway, 3825 Ohio Avenue, St. Charles, IL 60174.

Trade Name – Fire-Lite.

Product – Fire Alarm Equipment.

Pertinent Code Section(s) – Reference Standard RS 17-3, RS 4-6 (886-89-BCR).

Tests – UL 268.

Laboratory – Underwriters Laboratories, Inc.

Test Reports – UL File S911, Vol. 66, Sec. 1, Iss. January 8, 2001, revised September 5, 2002.

Description – Model CP355 is an ionization type smoke detector intended to detect an abnormal amount of smoke density in the area in which it is installed and to operate an alarm signal during this condition. This model is intended for open area air velocities up to 1200 ft./min.

Model Number	Description
CP355	Ion Smoke Detector

Pursuant to “Promulgation of the Rules relating to Material and Equipment Application Procedures” dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated October 7, 2002, F.P. Index 0210009.

Recommendation - That the above units be accepted on condition that all uses, locations and installations comply with the of New York City Building Code, specifically Subchapter 17, and with the Reference Standards RS 17-3 through 17-3C inclusive, the UL Listing, the manufacturer's instructions, the Fire Department Rules, and with the Electrical Code of the City of New York.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance FEBRUARY 13, 2003

Examined by Donald A. [Signature]