

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner
MEA 32-00-M

Report of Material and Equipment Acceptance Division

Manufacturer – Vesuvius-Premier, 101 Jonesborough Hwy., Erwin, TN 37650.

Trade Name – FireTherm Products – IntuBatt, IntuMastic, IntuMastic Plus, IntuCompound, IntuCollar, IntuPutty, IntuCoat, IntuStrap.

Product – Through-Penetration Firestopping.

Pertinent Code Section(s) – 27-345.

Prescribed Test(s) - RS 5-19 (ASTM E814).

Laboratory – Underwriters Laboratories Inc.

Test Report(s) – UL File R9242, R19005, R19057.

Description – UL listed and labeled through penetration firestopping products/systems shall be applied in accordance with Underwriters Laboratories Inc., system number listed below in achieving the required fire resistance rating.

- IntuCoat Coating Fill, Void or Cavity Material for use in through-penetration firestop system nos. CAJ-0066, CAJ-1307, CAJ-1312, CAJ-3161, CAJ-4044, WL-3147, and WL-7043.
- IntuMastic Sealant Fill, Void or Cavity Material for use in through-penetration firestop system nos. CAJ-0066, CAJ-1307, CAJ-1312, CAJ-2262, CAJ-3161, CAJ-4044, WL-3147, and WL-7043.
- IntuMastic Plus Sealant Fill, Void or Cavity Material for use in through-penetration firestop system nos. CAJ-2259, CAJ-2263.
- IntuStrap Wrap Strip Fill, Void or Cavity Material for use in through-penetration firestop system nos. CAJ-2262, CAJ-5129, CAJ-5131, CAJ-2264.
- IntuPutty Fill, Void or Cavity Material for use in through-penetration firestop system no. CAJ-2260.
- IntuCompound Fill, Void or Cavity Material for use in through-penetration firestop system nos. CAJ-1310, CAJ-4045, CAJ-3162, CAJ-8077, CAJ-8078, CAJ-1314, CAJ-1313, CAJ-5129, CAJ-5130, CAJ-5131, CAJ-2264.
- IntuCollar Firestop Device for use in through-penetration firestop system nos. CAJ-2258, CAJ-2261, WL-2187.
- IntuBatt Forming Material for use in through-penetration firestop system nos. CAJ-0066, CAJ-1307, CAJ-1311, CAJ-1312, CAJ-3161, CAJ-4044, CAJ-7054, CAJ-7055, CAJ-7056, WL-3147, and WL-7043.

System No.	F Rating Hour	T Rating Hour
CAJ-0036	3	3/4
CAJ-1307	3	0
CAJ-1311	3	1/2
CAJ-1312	3	0
CAJ-2259	3	1
CAJ-2260	2	2
CAJ-2262	2	2
CAJ-2263	3	3/4
CAJ-3161	3	0
CAJ-4044	3	0
CAJ-7054	2	0
CAJ-7055	2	0
CAJ-7056	2	0
W-L-3147	1,2	0, 3/4
W-L-7043	1,2	1,2

Recommendation - That the above described fill, void or cavity material used to fill the remaining voids in fire rated assemblies with the above described fire protection rating, where electrical trays, cables, mechanical piping or ductwork pass through the assembly, be accepted for use in such assemblies when installed in accordance with the manufacturer's application instructions. Suitable support angles and fasteners as required for respective assemblies shall be provided in accordance with manufacturer's recommendations. All shipments and deliveries of such materials shall be accompanied by a certificate or label, certifying that the materials shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance MAR 31 2000

Examined By S. Derkudam