



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 321-02-E Vol.5

Manufacturer: System Sensor, Unicorp. Division of Honeywell, Intl. Inc., 3825 Ohio Avenue, St. Charles, IL 60174

Trade Name(s): Silent Knight, 7550 Meridian Circle, Maple Grove, MN. 55369

Product: Fire Alarm Equipment

Pertinent Code Section(s): Subchapter 17 and Reference Standard RS17

Prescribed Test(s): UL 268

Laboratory: Underwriters Laboratories, Inc. (UL)

Test Report(s): UL Multiple Listing File S6173, issued July 21, 2005, revised January 10, 2006.

Description -

<u>System Sensor</u> <u>Model No.</u>	<u>Silent Knight</u> <u>Model No.</u>	<u>Description</u>
FSI-851	IDP-ION	Ionization Smoke Detector

Terms and Conditions: The above smoke detectors be accepted on condition that all uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17 and Reference Standard RS17-3. Furthermore, the installation and spacing shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL Standard.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance April 27, 2006.
Examined by Donald [Signature]