



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 321-05-E

**Manufacturer:** Stulz Air Technology Systems, Inc., 1572 Tilco Drive, Frederick, MD 21704.

**Trade Name(s):** Desicair.

**Product:** Desicant dehumidifier.

**Pertinent Code Section(s):** 27-770, 27-777.

**Prescribed Test(s):** RS 13-6 (ANSI B9.1), RS 13-11 (UL 1995).

**Laboratory:** MET Laboratories, Inc.

**Test Report(s):** MT 11899, dated November 8, 2005.

**Description** – Model ADU-2250-77-G dehumidifier with process blower and re-activation blower, rated 208 VAC/3PH/60Hz, permanently wired max. load including controls 16 amps.

**Terms and Conditions:** That the above described unit be accepted for indoor installation, under the following conditions:

1. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.
2. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 3/3/06

Examined by Supriya Ghose