

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

**Satish K. Babbar, R.A., Acting Commissioner
MEA 325-00-M**

Report of Material and Equipment Acceptance Division

Manufacturer – Rexan DSI, 1 Canal Road, South Hadley, Massachusetts 01075.

Trade Name – Duraprene.

Product - Wallcovering product.

Pertinent Code Section(s) - 27-348.

Prescribed Test(s) - RS 5-5 (ASTM E84); Toxicity.

Laboratory - SGS U.S. Testing Company

Test Report(s) - Report No. 142651 dated August 4, 2000 and #109333 dated June 10, 1998.

Description – Decorative and functional interior wallcovering, Duraprene design for interior finish applications. The material comprises reprocessed cellulose fibers from renewable resource farmed trees, pulped and bonded in latex under high compression, then sealed in chemical bond with a patented urethane sealant.

Flame Spread Rating - 0.

Smoke Developed Rating - 15.

Recommendation - That the above described wallcovering material be accepted as having interior finish usage, with Class A flame spread rating and smoke developed rating as indicated above. Upon exposure to fire, the material did not produce products of decomposition or combustion that were more toxic than those given off by wood or paper when decomposing or burning under comparable conditions. All shipments and deliveries of such materials shall, in addition, be accompanied by a tag, certifying that the materials shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance SEP 25 2000

Examined By S. Derkhal