

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner  
MEA 327-00-M

Report of Material and Equipment Acceptance Division

Manufacturer - Decoustics, 65 Disco Road, Toronto, Ontario M9W 1M2.

Trade Name - Decoustics ME/VATT.

Product - Acoustic Panel.

Pertinent Code Section(s) -27-348.

Prescribed Test(s) - RS 5-5 (ASTM E84); Toxicity.

Laboratory - NGC Testing Services, Anderson Testing Laboratories Inc.

Test Report(s) - AL #509, dated August 14, 2000 and NGC File FH-100 dated May 5, 2000.

Description - Decoustics type ME/VATT Claro finish acoustic panel, designed for interior and architectural noise control (Acoustic absorption). The panel has 25-mm (1") nominal thickness.

Flame Spread Rating	24
Smoke Density Rating	23

Recommendation - That the above described panel be accepted as having interior finish Class A, with flame spread rating as indicated above. Upon exposure to fire the material did not produce products of decomposition or combustion that were more toxic than those given off by wood or paper when decomposing or burning under comparable conditions. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance Nov 22, 2000

Examined By S. Deebharam