



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 330-05-M

Manufacturer: Centria 1005 Beaver Grade road, Moon Township, Pennsylvania 15108.

Trade Name(s): FORMAWALL DS, VERSAWALL and VERSAPANEL.

Product: Insulated exterior wall panels.

Pertinent Code Section(s): 27-232 and 27-335.1 (c).

Prescribed Test(s): RS 5-21 (UBC 17-6); RS 5-5 (ASTM E84); NFPA 259, toxicity, UBC 17-6.

Laboratory: Southwest Research Institute, Omega Point Lab of Intertek, Professional Services Industries, Inc.

Test Report(s): Omega Point Lab Report No. 15815-117783, RV 1, dated May 13, 2005.
SWRI Project No. 01.10594.01.001 dated July 2004.
SWRI Project No. 01.10935.02.025b dated April 2005.
SWRI Project No. 01.10934.01.621d dated March 2005.

Description: FORMAWALL DS, VERSAWALL and VERSAPANEL exterior insulated wall panels comprising minimum 26 gauge coated galvanized steel facings sandwiching a poured-in-place Pentane blown Polyurethane foam plastic core. The maximum field thickness of the insulation material shall be 2 inches for the FORMAWALL DS and VERSAWALL panels and 1-3/4 inch for the VERSAPANEL panels. The panels are to be fastened to noncombustible supports utilizing methods of attachment prescribed by the manufacturer and tested by Southwest Research Institute. Panels shall be separated from the interior spaces by a thermal barrier having at least a one-hour fire resistance rating.

Terms and Conditions: The above described insulated exterior wall panel systems comprising a thermal insulation which is not noncombustible and does not meet the requirements of Code Section 27-335.1 (a) or 27-335.1 (b) for use where noncombustible construction is required, be accepted for use in either new or existing noncombustible construction group I buildings. Installation shall be in accordance with Section 27.335.1 (c) following manufacturer supplied instructions. All shipments and deliveries of such materials shall be provided with a label or tag certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance November 18, 2005

Examined By Sjun Derphudam