

**CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner

**MEA 331-00-E  
Report of Materials and Equipment Acceptance Division**

**Manufacturer – Rheem Air Conditioning Division for RUUD, P.O. Box 17010, Fort Smith, AR 72917-7010.**

**Trade Name – RUUD.**

**Product – Combination gas heat/electric cooling.**

**Pertinent Code Section(s) – 27-770, 27-777, 27-800, RS 14-6 (ANSI Z223.1).**

**Prescribed Tests – RS 13-6 (ANSI B9.1), RS 13-11 (UL1995), RS 14-6 (ANSI Z21.47).**

**Laboratory – Underwriters Laboratories Inc.**

**Test Report – File SA 7930, dated July 1, 1998.**

**Description – Rooftop combination gas heating/electric cooling units, Model UKKB designed for outdoor installation. Heating section operates on natural gas and cooling system employs refrigerant R-22. Heating section is provided with main burner, heat exchanger assembly, automatic spark ignition burner and induced draft blower assembly, and safety controls. Units, with model numbers, cooling and heating capacities, are listed below:**

<b>Model No.</b>	<b>Mfr.'s Specified Nominal Cooling Capacity (BTUH)</b>	<b>Input Heating Rating BTUH</b>
UKKB-A102*	102,000	15E = 150,000/112,000 22E = 225,000/112,000
UKKB-A150*	150,000	25E = 252,000/126,000
UKKB-A180*	180,000	30E = 300,000/150,000 35E = 350,000/175,000
UKKB-A240*	240,000	40E = 400,000/200,000

**Note: \* - Can have any of the following suffixes depending on furnace inputs: 15E, 22E, 25E, 30E, 35E, and 40E.**