



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 336-07-E

Manufacturer: The Delfield Company, 980 South Isabella Road, Mt. Pleasant, Michigan 48858

Trade Name(s): Delfield/Shelleyglas/Shelleysteel/Shelleyspeed, Shelleybasic/Versa Drawer/Mark 7/Liquitec

Product: Commercial refrigerators & freezers (self-contained)
MEA Index #600 – Refrigerator Systems & Freezers

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 14-6 (UL 471)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File SA4769 dated June 26, 1978, revised March 20, 1998.

Description: Appliances are self contained and remote cord-connected commercial refrigerators intended for connection to a 120 VAC, 60 Hz, single-phase supply source. The units have an onboard compressor and onboard refrigerating circuit. All models are intended to be elevated on legs or casters. The units are equipped with air-cooled condensers, and the refrigeration circuits have capillary tubing or expansion valves.

Units with description and model numbers are provided on the following pages.

Product Covered:

MILK COOLERS	Models: DFD-8, DFD-12, DFD-16, DFS-8, DFS-12,DFS-16
DROP-IN ICE CREAM CABINETS	Models 225 and 227, with or without prefix N, with or without suffix L
ICE CREAM CABINETS WITHOUT SYRUP RAIL	Models 13WC, with or without prefix F, followed by suffixes 32 through 68
ICE CREAM CABINETS WITH SYRUP RAIL	Models 13BC, with or without prefix F, followed by suffixes 32 through 68
REFRIGERATOR BASE EQUIPMENT STANDS	Models 29, with or without prefix F, followed by suffix 30 through 132 with or without additional suffix numbers or letters
FREEZER BASE EQUIPMENT STANDS	Models 26, with or without prefix F, followed by suffix 30 through 96 with or without additional suffix numbers or letters
REFRIGERATED BASE CHEF STANDS	Models 17, with or without prefix F, followed by C, followed by suffix 30 through 132, with or without additional suffix numbers or letters
REFRIGERATED WORK TABLES	Models 18, with or without prefix F, followed by WC, followed by suffix 30 through 132, with or without additional suffix numbers or letters
SALAD TOP REFRIGERATORS MEGA TOP REFRIGERATORS RAISED RAIL PIZZA TABLES	Models 18, with or without prefix F, followed by MC, SC, DC or RC, followed by suffix 30 through 132, with or without additional suffix numbers or letters
FREEZER WORK TABLES	Models 18, with or without prefix F, followed by FC, followed by suffix 30 through 96, with or without additional suffix numbers or letters
MECHANICALLY COOLED COLD PANS FROST TOPS AND HOT/COLD PANS	Models 81, 82 or 86, followed by suffix 16 through 144, with or without suffixes -1 through -6 or N, or prefix CTB or N, with or without suffix B, Br or EF
FORCED-AIR DROP-IN MECHANICAL COOLED COLD PANS	Models 81, with or without suffix 1 through 6, followed by suffixes 31 through 138 with suffix FA, with or without prefix N
DROP-IN DISPLAY CASES SERVIEW DISPLAY CASES	Models 5 or 15, with or without prefix F, followed by M, P or S, followed by suffix C, followed by 36, 48, 60 or 72, with or without suffix D or N

FROST TOP SERVING COUNTERS REFRIGERATED COLD PAN SERVING COUNTERS	Models KCFT, KCSC, SCFT or SCSC, with or without suffix 28 though 138, with or without suffix B or EF
MILK COUNTERS	Models KCM or SCM, followed by suffixes 36 though 138
ALL PURPOSE COUNTERS ICE CREAM COUNTERS MILK AND ICE CREAM COUNTERS	Models KC or SC followed by suffix F or FM, with or with suffix 2, followed by suffix -18 though 138. Models SCF-32, SCF-48
MILK OR BEVERAGE DISPENSERS BUILT-IN MILK OR BEVERAGE DISPENSERS	Models MFSC, N, N6, N10, N14 or NDF, followed by Hyphen and <u>one</u> to <u>four</u> digits, with or without a Hyphen and <u>two</u> digits, with or without suffix 6
NLFAC SERIES MILK OR BEVERAGE DISPENSERS	Model NLFAC, followed by suffix -8, -12 or -16
REFRIGERATED CURVED GLASS DISPLAY CASES	Models 5 and 520 with or without prefix DI, followed by suffix 32 through 76, followed by suffix -CD, -CR, -OF, -OR, -SD, -SR, -SSD or -SSR, with or without <u>two</u> or <u>four</u> additional suffix numbers
PREP TABLES REFRIGERATED WORK TABLES	Model 186 with or without prefix V, VI or F, followed by suffix 30 through 132, with or without suffix DOM, PHD, P32 or PT, followed by suffix AC, EB, B, MC or CP, with or without additional suffix numbers or letters
MOBILE FREEZER SPEED-LINE MODULES	Model SPF, followed by suffix -24 through -64, with or without additional suffix letters or numbers
MOBILE REFRIGERATOR SPEED-LINE MODULES	Model SPR, followed by suffix -24 through -64, with or without additional suffix letters or numbers
VERSA DRAWER MULTI- TEMPERATURE REFRIGERATORS	Model F17, followed by -82 through -92, followed by suffix-VD with or without suffix -L or -R; Model F18FD, followed by suffix -50 through -92 with additional suffix -L or -R; Model F29, followed by -82 through -92, followed by suffix -VD, followed by suffix -L or -R; Model 186, followed by suffix 50 or 82, followed by suffix VD, followed by suffix L or R
RAPID PULL DOWN REFRIGERATOR AND FREEZERS	Models T5 and T14D
AIR-CURTAIN REFRIGERATORS	Models AC or ACR, followed by suffix 12 or 26, with letters -A, -D, -G, -H or -S in various combinations
CUSTOM-BUILT FOOD SERVICE COUNTERS	Model Mark 7, followed by five to ten suffix numbers or letters.

Terms and Conditions: The above-described commercial refrigerators are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical Code requirements.
2. Adequate supply of fresh air for ventilation shall be provided into room or space enclosing equipment.
3. The installation shall not obstruct access for operation and servicing.
4. No flammable material (except electrical insulation) shall be located in the machine or wiring compartments unless specified.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
7. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance May 29, 2008

Examined by Sam Derfucker