



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 338-07-M

Manufacturer: Kofulso Co., Ltd.
377-8 Gumgog Dong
Seogu Incheon, KOREA

Trade Name(s): Easyflex

Product: Flexible water connectors

Pertinent Code Section(s): RS 16 (P102.2[a], P102.2[b])

Prescribed Test(s): P102.2(b) and IAPMO PS74-95, IAPMO PS 448-92
and TPPN #2/98

Laboratory: IAPMO Research & Testing, Inc.

Test Report(s): IAPMO Report File No. 5293, dated July 2007 and
Report #885-T07004A, dated May 3, 2007.

Description: This product is manufactured in various sizes, lengths and metal-end fittings for hot or cold water applications that consist of an inner tube, which may or may not have an outer braided cover. This product is not designed for use in inaccessible locations or below ground. This product is to be installed using 2 - 3 wraps of Teflon tape (included) on nipples.

Manufacturer requires the following installation procedure:
After applying Teflon tape, bend connector slowly into approximate shape to join water supply to the inlet nipple of the water heater or inlet of the softener bypass and connect snugly. At last, repeat process for outlet side of water heater or outlet side on the bypass of softener.

Model No.	Description
EFWC-034-SA-034-12	3/4" FIP X 3/4" FIP X 12"
EFWC-034-SA-034-15	3/4" FIP X 3/4" FIP X 15"
EFWC-034-SA-034-18	3/4" FIP X 3/4" FIP X 18"
EFWC-034-SA-034-24	3/4" FIP X 3/4" FIP X 24"
EFWC-034-SA-034034-15	3/4" FIP X 3/4" MIP X 15"
EFWC-034-SA-034034-18	3/4" FIP X 3/4" MIP X 18"
EFWC-034-SA-034034-24	3/4" FIP X 3/4" MIP X 24"
EFWC-034-CSC-15	3/4" FIP X 3/4" PUSH FIT X 15"
EFWC-034-CSC-18	3/4" FIP X 3/4" PUSH FIT X 18"
EFWC-034-CSC-24	3/4" FIP X 3/4" PUSH FIT X 24"
EFWC-034-NI-034001-18	3/4" FIP X 1" FIP X 18"
EFWC-034-NI-034001-24	3/4" FIP X 1" FIP X 24"
EFWC-034-NI-034114-15	3/4" FIP X 1-1/4" FIP X 15"
EFWC-034-NI-034114-18	3/4" FIP X 1-1/4" FIP X 18"
EFWC-034-NI-034114-24	3/4" FIP X 1-1/4" FIP X 24"
EFWC-001-SA-001-12	1" FIP X 1" FIP X12"
EFWC-001-SA-001-18	1" FIP X 1" FIP X18"
EFWC-001-SA-001-24	1" FIP X 1" FIP X24"
EFWC-001-NI-001114-12	1" FIP X 1-1/4" FIP X 12"
EFWC-001-NI-001114-15	1" FIP X 1-1/4" FIP X 15"
EFWC-001-NI-001114-18	1" FIP X 1-1/4" FIP X 18"
EFWC-001-NI-001114-24	1" FIP X 1-1/4" FIP X 24"
EFWC-114-SA-114-18	1-1/4" FIP X 1-1/4" FIP X 18"
EFWC-114-SA-114-24	1-1/4" FIP X 1-1/4" FIP X 24"
EFWC-112-SA-112-18	1-1/2" FIP X 1-1/2" FIP X 18"
EFWC-112-SA-112-24	1-1/2" FIP X 1-1/2" FIP X 24"
EFWC-002-SA-002-18	2" FIP X 2" FIP X 18"
EFWC-002-SA-002-24	2" FIP X 2" FIP X 24"

Terms and Conditions: The above flexible water connectors are accepted with the following conditions:

1. The plumbing fixture shall have its own control valve.
2. The connectors shall be used only in exposed locations.
3. The connector used shall be accurate length for a specific installation, and never exceed a length of twenty-four (24) inches.

4. The connector shall be used singularly. Coupling two or more connectors is not permitted.
5. All shipments and deliveries of such equipment shall, in addition, be accompanied by a tag, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance November 20, 2007

Examined By Simon Derkshorn