



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 342-07-M

Manufacturer: RJF International Corporation
700 BF Goodrich Road
Marietta, OHIO 45750

Trade Name(s): RESONANCE

Product: Decorative wall covering material

Pertinent Code Section(s): 27-348

Prescribed Test(s): RS 5-5 (ASTM E-84), UPITT Toxicity

Laboratory: Southwest Research Institute (SwRI)
Anderson Laboratories (AL)

Test Report(s): SwRI – Project 01.11810.01.205b and Project 01.11810.01.205c, dated August 21, 2006 and Project 01.11811.01.422, dated August 18, 2006.

Description: Decorative TPO wallcoverings, 14 oz/psy Type II, typically comes in width of 52" – 54" and in 30 yd. rolls. Material can be provided custom-made in other widths and lengths. Material is offered in a multitude of patterns and colors.

Flame Spread Rating: < 15
Smoke Development Rating: < 5

Terms and Conditions: The above-described wallcovering material is accepted with the following conditions.

1. Material is for interior finish with Class 'A' flame spread rating, as indicated above.
2. All shipments and deliveries of such materials shall be provided with a label, suitably placed, certifying that the materials shipped or delivered are equivalent to those tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance November 13, 2007.

Examined By Siun DerPhodan