



NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 343-89-M Vol. 2

Manufacturer: Applegate Holdings, LLC
1000 Highview Drive
Webberville, MI 48892

Trade Name(s): Applegate

Product: Cellulose Thermal & Acoustical Insulation Material
MEA Index #650-20 – Insulation Material

Pertinent Code Section(s): 27-232 (Definitions-Noncombustible), 27-335.1 and
27-348

Prescribed Test(s): RS 5-5 (ASTM E84), Toxicity

Laboratory: United States Testing Company, Inc. (UST)
Anderson Laboratories, Inc. (AL)

Test Report(s): UST #IP86-0100 dated April 15, 1986.
AL Test #130 dated March 27, 1990

Description: Cellulose thermal and acoustical insulation material, designated fire resistance chemicals and dry adhesives. When spray is applied to the cavity of walls, the material conforms to wall substrate and surrounds pipes, wires and other obstructions.

Flame spread rating: 15
Smoke developed rating: 0

Terms and Conditions: The above-described insulation material is accepted for use with the following conditions:

1. The material may be used in either new or existing noncombustible construction Group I or combustible Group II buildings.
2. Installation shall be in accordance with Section 27-335.1 and manufacturer's supplied instructions.
3. All shipments and deliveries of such material shall have the MEA number printed on packages, certifying that the material shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance July 29, 2008

Examined By Simon Derkshidam