

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 347-03-E

Report of Materials and Equipment Acceptance Division

Manufacturer – Lennox Industries, Inc., 200 S. 12th Avenue, Marshalltown, IA 50158.

Trade Name – Elite.

Product – Self-contained air conditioning units.

Pertinent Code Section(s) – 27-770, 27-777.

Prescribed Tests – RS 13-11 (UL1995), RS 14-6 (ANSI Z21.47.1993).

Laboratory – Underwriters Laboratories Inc.

Test Report – File SA11694 dated January 9, 2002.

Description – Self-contained air conditioning units, model HSX designed for outdoor installation. R-22 is the refrigerant used for the system. Unit consists of hermetic sealed compressor, air cooled condenser with fan, and safety controls. Units, with model numbers and nominal cooling capacities, are listed below:

Model No.	Mfr.'s Specified Nominal Cooling Capacity (Tons)
HSX*12-024	2.0
HSX*12-030	2.5
HSX*12-036	3.0
HSX*12-042	3.6
HSX*12-048	4.0
HSX*12-060	5.0

Note: * May be any letter A thru Z.

Recommendation - That the above described self-contained air conditioning units, be accepted for outdoor installation, when utilizing Refrigerant R-22, under the following conditions:

1. All equipment shall be furnished with permanently affixed metal tags, stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
2. All shipments and deliveries of such equipment shall be accompanied by a certificate or label certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 11/28/03

Examined by Sujan M. Dusew