



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 35-93-E Vol. 23

Manufacturer: Simplex Time Recorder Company, 100 Simplex Drive, Westminster, MA 01441-0001

Trade Name(s): Simplex

Product: Fire alarm equipment

Pertinent Code Section(s): Reference Standard RS-17, Subchapter 17

Prescribed Test(s): UL 38

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File S772, Vol. 1, Sec. 3, Project 91NK12155, dated August 9, 1991 and revised November 9, 2005.
UL letter dated September 19, 2006.

Description: Fire alarm equipment as follows:

Model No.	Description of Product
2099-9101	Non-coded Manual Station with normally-open alarm contacts and normally-open annunciator contacts.
2099-9102	Non-coded Manual Station with normally-open alarm contacts and normally-closed annunciator contacts.
2099-9103	Non-coded Manual Station with break glass and hammer with normally-open alarm contacts.
2099-9104	Non-coded Manual Station with break glass and hammer with normally-open alarm contacts and normally-open annunciator contacts.
2099-9105	Non-coded Manual Station with break glass and hammer with normally-open alarm contacts and normally-closed annunciator contacts.

Model No.	Description of Product
2099-9754	Non-coded Manual Station with normally-open alarm contacts.
2099-9755	Non-coded Manual Station with normally-open alarm contacts with "Local Fire Alarm" marking.
2099-9756	Non-coded Manual Station with push bar and pull-down handle with normally-open alarm contacts.
2099-9757	Non-coded Manual Station with push bar and pull-down handle with normally-open alarm contacts and normally-open annunciator contacts.
2099-9758	Non-coded Manual Station with push bar and pull-down handle with normally-open alarm contacts and normally-closed annunciator contacts.
2099-9762	Non-coded Manual Station with institutional cover with normally-open alarm contacts.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated April 10, 2007, F.P. Index #0609044A.

Terms and Conditions: The above units are accepted on condition that:

1. All above models shall be mounted to an approved outlet box or back box of metallic construction.
2. Model 2099-9762 shall be used only in Institutional Occupancies (Occupancy Group H-1 only, as defined in New York City Building Code) and the required key for activation of the pull station shall be in possession of authorized personnel/s at all times and immediately available for use in an emergency.
3. All uses, configurations, arrangements and functions, application, locations and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17 and Reference Standard 17-3. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA-72 and UL Standard.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance June 6, 2007
Examined By Donald [Signature]