



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 352-01-E Vol. 2

Manufacturer: Tyco Fire Products LP, 8902 Interstate 27, Lubbock, TX 79403

Trade Name(s): Tyco Fire Products

Product: Quick and Standard Response Concealed Dry Pendent Sprinklers

Pertinent Code Section(s): RS 17-6A

Prescribed Test(s): RS 17-6A (UL199)

Laboratory: Underwriters Laboratories Inc.

Test Report(s): File Ex5985, Project Nos. 00NK47105,01NK50153, 02NK47308, 03NK47308, 03NK18028, 03NK21068, 04NK29013, 03NK30454, Issued July5, 2001, Revised May 14, 2004, UL Letter dated 2/22/06

Description – Dry Sprinklers TY3535, TY3539 and TY3555 for use in Fire Suppression Systems.

SIN	Type	K-Factor	Temp. Rating	Finishes
TY3535	Quick Response Dry Pendent Concealed Sprinkler, Bulb Type with Maximum Rated Pressure of 175psi.	5.6	155 and 200F	Cover Plate: Chrome Plated, Brass Plated, White Painted or Custom.

TY3539	Quick Response, Extended Coverage Dry Pendent Concealed Sprinkler, Bulb Type with Maximum Rated Pressure of 175psi	5.6	155 and 200F	Cover Plate: Chrome Plated, Brass Plated, White Painted or Custom.
TY3555	Standard Response Dry Pendent Concealed Sprinkler, Bulb Type with Maximum Rated Pressure of 175psi	5.6	155 and 200F	Cover Plate: Chrome Plated, Brass Plated, White Painted or Custom

Pursuant to "Promulgation of the Rules relating to Materials and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated March 14, 2006, FP Index No#: 0603012

Terms and Conditions: That the above sprinklers, be accepted on condition that

1. All uses, applications and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standard 17-2. Further, the installation shall be in accordance with the manufacturer's recommendations and UL 199.
2. UL and manufacturer's maintenance procedures and limitations shall be complied with:

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance May 4, 2006.
 Examined by Donald J. J.