



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 356-06-E

Manufacturer: System Sensor, Unincorporated Division of Honeywell International Inc., 3825 Ohio Avenue, St. Charles, IL 60174

Trade Name(s): System Sensor

Product: Fire alarm equipment

Pertinent Code Section(s): RS 17-3, RS 4-6 (886-89BCR), Subchapter 17

Prescribed Test(s): UL 268

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): S911 Volume 116, Section 1, Issued June 2, 2005, revised December 16, 2005.

Description: Model Number 67-034 is an ionization smoke detector.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Acceptance Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated June 2, 2006, F. P. Index#0602074.

Terms and Conditions: The above equipment is accepted provided that:

1. All uses, configurations, arrangements and functions, application and installations shall comply with the provisions of the New York City Building Code, specifically Subchapter 17 and Reference Standard 17-3. Further, the installation and pacing of detectors shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL standard 268.
2. The above product shall be used only with approved/accepted and compatible control panels.
3. Periodic maintenance and sensitivity tests shall be conducted in accordance with the regulations of the Fire Department.
4. UL and manufacturer's maintenance procedures and limitations shall be complied with.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance

July 28, 2006

Examined by

Donald J. Ff