



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 356-06-E Vol.2

Manufacturer: System Sensor
3825 Ohio Avenue
St. Charles, IL 60174

Trade Name(s): Honeywell

Product: Fire alarm equipment

Pertinent Code Section(s): RS 17-3, RS 4-6 (886-89BCR)

Prescribed Test(s): UL 268

Laboratory: Underwriters Laboratories

Test Report(s): UL multiple listing file no. SI/96 issued 8-17-05

Description: Honeywell System Sensor

Model Number	System Sensor Model No.	Description
TC907A1001	67-034	Ionization Smoke Detector

Terms and Conditions:

1. All uses, configurations, arrangements and functions, application and installations shall comply with the provisions of the New York City Building Code, specifically Subchapter 17 and Reference Standard 17-3. Further, the installation and spacing of detectors shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL standard 268.

2. The above product shall be used only with approved/accepted and compatible control panels.
3. Periodic maintenance and sensitivity tests shall be conducted in accordance with the regulation of the Fire Department.
4. UL and manufacturer's maintenance procedures and limitations shall be complied with.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance August 3, 2007.

Examined by Donald [Signature]