



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 356-06-E Vol. 3

Manufacturer: System Sensor, Unincorporated Div. Of Honeywell Int'l. Inc., 3825 Ohio Avenue, St. Charles, IL 60174

Trade Name(s): Fike Protection Systems

Product: Fire alarm equipment

Pertinent Code Section(s): RS 17-3, RS 4-6 (886-89-BCR), Subchapter 17

Prescribed Test(s): UL 268

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File S911, Volume 116, Section 1, issued June 2, 2005, revised September 14, 2006

Description: Ionization smoke detector, Model No. 67-033.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated January 26, 2007, F.P. Index #0701029.

Terms and Conditions: The above smoke detector is accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations comply with the provisions of New York City Building Code, specifically Subchapter 17 and Reference Standard 17-3.

2. Unit shall be installed in accordance with the manufacturer's recommendation, NFPA 72 and UL standard 268.
3. Unit shall be used only with approved and compatible control panels and accessories.
4. Periodic maintenance and sensitivity tests shall be conducted in accordance with the regulations of .the Fire Department.
5. UL and manufacturer's maintenance procedures and limitations shall be complied with.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance March 21, 2007.

Examined By Donald [Signature]