

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 367-03-E

Report of Material and Equipment Acceptance Division

Manufacturer – CFM Corporation, 1000 East Market Street, Huntington, IN 46750.

Trade Name(s) – Majestic, Vermont Castings, Pyromaster.

Product - Factory-built fireplaces.

Pertinent Code Section(s) -27-848.01, 27-848.02 and 27-848.08.

Prescribed Test(s) - RS 15-15 (UL 127 Modified).

Laboratory – Underwriters Laboratories Inc.

Test Report(s) – File MH6018 dated November 13, 2003.

Description – these are factory-built fireplaces consisting of a fire chamber, chimney and chimney components. The fireplaces are made in one basic size with a center hearth opening incorporating an integral grate and refractory brick fire chamber.

Product Covered:

Factory-built fireplaces models: BR36i, BC36i, BR42i, BC42i, HBC36, HBR36, HBC42, WMC36, WMC42, SHR52, SHR48, SHR42A, SHR36, SR36A, SC36A, SR42A, SC42A. ODSR36A, ODSR42A, EWF36A, CR36R, CR36L, BFC36.

Note: Minimum installed clearances from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.

Recommendation - That the above described factory-built fireplaces, be accepted for use as supplemental heating and decorative purposes. The installation of the above described units shall be in accordance with manufacturer supplied instructions and the Building Code. Furthermore, the unit shall be vented in accordance with Section 27-856 of the Building Code. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

1/26/04

Examined By

Supriya Sen