

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

MEA 373-03-E
Report of Materials and Equipment Acceptance Division

Manufacturer – Aigi Sanyo Co., Ltd, Nezame 31, Aigi Bldg., Nawa-Cho Tokai Aichi 476, Japan.

Trade Name – Aigi Sangyo.

Product – Commercial electric conveyORIZED deep fat fryers.

Pertinent Code Section(s) – 27-787, 27-792.

Prescribed Tests – RS 14-6 (UL 197).

Laboratory – Intertek ETL Semko.

Test Report – No. 3046715, dated December 18, 2003.

Description – Commercial electrical fryers, as listed below. Unit comprises heating elements, thermostat, pilot light, on-off switch, limit control, and terminal block. Units have several alternate timing cycles and control functions.

Product Covered: Model #HTA-1600 S/N L539.

Electrical Ratings: 208 VAC, 50A, 3 phase, 60 Hz.

Note: Minimum installed clearances from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.

Recommendation - That the above commercial conveyORIZED fryer, be accepted, under the following conditions:

1. Unit shall be installed in accordance with manufacturer's instructions, New York City Building and Electrical Code requirements.
2. Cooking equipment shall be installed under hoods that vent to the outside and comply with Reference Standard RS 13 requirements of the New York City Building Code and have a fire suppression system complying with Reference Standards RS 13-2 and RS 13-3 with open heads and capable of simultaneous discharge and manual release. The Fire Suppression system exclusively used for cooking equipment shall be filed with the Buildings Department and examined and approved by the Fire Department.

3. Adequate supply of fresh air shall be provided into room or space enclosing equipment for unit ventilation and combustion requirements.
4. The installation shall not interfere with accessibility for operation and servicing.
5. For grease removal, suitable baffle type grease filters, MEA accepted, shall be installed.
6. All shipments and deliveries of such equipment shall be accompanied by a certificate or label certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
7. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 1/26/04
Examined by 