



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 377-06-E

Manufacturer: Denso Sales California, Inc.
3900 Via Oro Avenue
Long Beach, CA 90623

Trade Name(s): MovinCool

Product: Single-packaged air conditioners
Index #20 – Air Conditioning Equipment

Pertinent Code Section(s): 27-777

Prescribed Test(s): RS 13-11 (UL 1995)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File SA32073, dated May 9, 2006.

Description: Ceiling-mounted, self-contained, single-packaged air conditioners. Refrigerant R-22 is used for the system. Unit is comprised of hermetically sealed compressor, air-cooled condenser, evaporator coil with direct drive blower, expansion valve and safety controls. Unit, with model number and cooling capacity, is listed below:

Model	Cooling Capacity (Btu/hr)
MovinCool CM12	10,500

Terms and Conditions: The above-described air-conditioner units are accepted under the following conditions:

1. Units shall use only Refrigerant R-22.
2. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
3. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 2/9/08

Examined By [Signature]