



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 377-07-E Vol. 2

Manufacturer: Lennox Hearth Products
1110 West Taft Avenue
Orange, CA 92865

Trade Name(s): Lennox

Product: Gas-fired, direct vent fireplace heaters
MEA Index #300 – Fire Place

Pertinent Code Section(s): Subchapter 14 and Reference Standard RS 14

Prescribed Test(s): RS 14-6 (ANSI Z21.88-2005, Z21.88a-2007)

Laboratory: OMNI-Test Laboratories, Inc.

Test Report(s): Certificate #116-F-28-5, issued February 8, 2005.

Description: Direct-vented gas fireplace heaters.

Model No.	Heat Input (Btu/hr)	Width of Unit
MPD35ST	30,000	35" Nominal
MPD35PF	30,000	35" Nominal

Terms and Conditions: The above-described direct-vent fireplace heaters are accepted for operation under the following conditions:

1. Units are for through-the-wall installation only.
2. Units shall use natural gas only.
3. Units shall be installed by a licensed plumber only, who shall insure that installation is provided with required unobstructed vent-opening and that all Gas Company requirements for this type of installation are strictly enforced.
4. If steel flue tube passes through a combustible wall, it must pass through a double metal thimble that is two inches larger than the flue.
5. Units shall not be installed behind doors, in an alcove or at locations where curtains or drapes can come into contact with them.
6. Gas pressure regulator shall be installed and gas inlet pressure shall be adjusted by the installer to give inlet pressure at the burner orifice recommended by the manufacturer.
7. A tag must be permanently affixed to the equipment stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
8. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
9. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
10. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance June 10, 2008
Examined By Donald [Signature]

