

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner  
MEA 38-00-E

Report of Material and Equipment Acceptance Division

Manufacturer – Mile High Equipment Company, 11100 East 45<sup>th</sup> Avenue, Denver, Colorado 80239.

Trade Name – Ice-O-Matic.

Product – Commercial ice-making equipment - remote systems.

Pertinent Code Section(s) – 27-771, 27-772.

Prescribed Test(s) - RS 14-6 (UL 563).

Laboratory – Underwriters Laboratories Inc.

Test Report(s) – File SA3887, dated May 30, 1986, revised November 2, 1999, September 13, and 14, 1999, January 7, 2000.

Description – Commercial ice making equipment. Water is frozen in the evaporator which is shaped to form ice cubes. A timer initiates a hot gas cycle when the desired cube thickness is obtained. Machine compartment contains expansion valve, compressor, drier, float valve, and high and low pressure control. Evaporator compartment is equipped with evaporators, control box and water pump. They are not intended for outdoor use.

**PRODUCT COVERED:**

Remote icemakers constant storage means less condenser models ICE (0500\*, 0606\*, 0806\*, 1006\*, 1007\*, 1406\*, 1407\*, 1806\*, 1807\*, 2106\*, 2107\*)R.

- Notes:
1. (\*) may be the letter F, H or J.
  2. Model numbers may be followed by additional letters and/or numbers.

Recommendation - That the above commercial ice makers be accepted, under the following conditions:

1. Units shall be operated in accordance with manufacturer's instructions and New York City Electrical Code requirements.
2. Adequate supply of fresh air shall be provided into room or space enclosing equipment for ventilation.
3. The installation shall not interfere with accessibility for operation and servicing.
4. No flammable material (except electrical insulation) shall be located in the machine or wiring compartments unless specified.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.
6. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 5/25/2000  
Examined By Chris Alford