



**Report of Materials and
Equipment Acceptance Division**

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 381-06-M

Manufacturer: Gladding Corporation, 1441 Dolly Madison Boulevard, McLean, VA 22101

Trade Name(s): Fibre-C

Product: Fiber-reinforced exterior wall panel

Pertinent Code Section(s): 27-232 (non-combustibility); C26-503–Article for Fire Resistance

Prescribed Test(s): RS 5-5 (ASTM E136)

Laboratory: Architectural Testing

Test Report(s): Report No. 65921.01-06-31, dated June 27, 2006

Description: A cement-based glass-fiber-reinforced cladding panel Fibre-C for rain screen is intended for use on single and multi-story building facades.

Terms and Conditions: The above-described cement-bonded particleboard material is accepted for usage where Building Code requires non-combustibility. All shipments and deliveries of such material shall be accompanied by a certificate or label certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Note: In accordance with section 27-131 (d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with code requirements of or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance August 2, 2006
Examined by Siun Derphidan