



NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 382-94-E Vol. 8

**Manufacturer:** Signal Communications Corporation, 4 Wheeling Avenue, Woburn, MA 01801

**Trade Name(s):** Sigcom

**Product:** Fire alarm pull stations and back box

**Pertinent Code Section(s):** RS17-3, 3A, 3B; RS17-5 and Subchapter 17

**Prescribed Test(s):** UL 38

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL File S5654, issued October 21, 1994, revised April 19, 2006. UL Letter dated December 18, 2006

**Description:** Manual fire alarms pull stations.

All models are for indoor use. All models may be used in outdoor applications when installed with Model SGB-32C or Model SGB-32CD cast box and supplied gaskets and are rated NEMA 3R.

SG-42 and SG-44 contact ratings 2A @ 24VDC, 240VAC and 5A @ 120VAC. Stations have an operating temperature range of -40°F to 150°F (-40°C to 66°C).

Models are: **SG-42SK1, SG-42SK2, SG-42CXX1 and SG-42CXX2**  
**SG-44SK1, SG-44SK2, SG-44CXX1 and SG-44CXX2**

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated March 7, 2007, F.P. Index #0702006A.

**Terms and Conditions:** The above-described units are accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations shall comply with all applicable provisions of the New York City Building Code, specifically Subchapter 17 and Reference Standard RS 17-3.
2. The installation and use shall be in accordance with the manufacturer's recommendations, NFPA-72 and UL-standard.
3. Only those models painted red shall be permitted.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance March 30, 2007  
Examined By Donald J. [Signature]