

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 388-02-E

Report of Material and Equipment Acceptance Division

Manufacturer – System Sensor, 3825 Ohio Avenue, St. Charles, IL 60174.

Trade Name(s) – Honeywell.

Product – Fire Alarm Equipment.

Pertinent Code Section(s) – RS 17-3, RS 4-6 (886-89-BCR).

Test(s) – UL 268.

Laboratory – Underwriters Laboratories Inc.

Test Report(s) – UL File S911, Volume 51, Section 1, issued January 12, 2000, revised September 25, 2002.

Description – The product is intended to detect an abnormal amount of smoke density in the area in which it is installed and transmit a signal proportional to the amount of smoke being sensed to a control panel. Intended for open areas with air velocities.

Model Number	Description
TC844A1015, TC808B1050	Smoke Detector, Photoelectric type
TC806B1068, TC840M1013	Smoke Detectors with integral heat detectors

Pursuant to “Promulgation of the Rules relating to Material and Equipment Application Procedures” dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated November 4, 2002, F.P. Index 0210071.

Recommendation - That the above equipment be accepted provided that all uses, locations, and installations shall comply with Article 17, Reference Standard RS-17 through RS 17-5 of the New York City Building Code, the Electrical Code of the City of New York, applicable Fire Prevention Directives, and the manufacturer’s instructions.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance FEBRUARY 27, 2003

Examined by 