

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 39-03-E

Report of Material and Equipment Acceptance Division

Manufacturer – Anetsberger Brothers, Inc, 180 North Anets Drive, Northbrook, IL 60002.

Trade Name(s) – Anets.

Product – Gas fired commercial outdoor grill.

Pertinent Code Section(s) – 27-800, 27-826, RS 14-2 (ANSI Z223.1).

Prescribed Test(s) -RS 14-6 (ANSI Z83.11 1996).

Laboratory – Intertek Testing Services.

Test Reports – See table below.

Description – Units comprise main burners, pilot burners, safety shutoff devices, thermostats and pressure regulators. Models, with their ratings are listed below:

Product	Model	Rating BTUH	Fuel	Report Nos.
Outdoor Gas Grill	MCB-30	64,500	Natural	276-1056-97-02 276-2460-99-07
Outdoor Gas Grill	MCB-36	79,500	Natural	276-1056-97-02 276-2460-99-07
Outdoor Gas Grill	MCB-48	96,000	Natural	276-1056-97-02 276-2460-99-07
Outdoor Gas Grill	MCB-60	114,000	Natural	276-1056-97-02 276-2460-99-07
Outdoor Gas Grill	MCB-72	129,000	Natural	276-1056-97-02 276-2460-99-07

Recommendation - That the above commercial outdoor grills be accepted, when fired by natural gas only, under the following conditions.

1. Units shall be installed in accordance with manufacturer's instructions and National Fuel Gas Code requirements.
2. All gas line connections shall be made and equipment gas input settings shall be set by the licensed plumber installing unit.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.
4. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 3/24/03

Examined By Shyam. K. Menon