

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner
MEA 390-00-E

Report of Material and Equipment Acceptance Division
Manufacturer - System Sensor, A Division of Pittway, 3825 Ohio Avenue,
St. Charles, IL. 60174

Trade Name(s) - System Sensor.

Product - Fire Alarm Equipment.

Pertinent Code Section(s) - RS 17-3, RS 4-6 (886-89-BCR).

Test(s) - UL 268A.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S911, Project 90NK1703, Volume 26, Section 1, issued August 20, 1990, revised August 24, 2000 and UL letter dated October 4, 2000.

Description - System Sensor's Smoke-Automatic fire detector as follows:

Model No.	Description
DH200RP	Smoke-Automatic Fire Detector for duct applications

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated October 18, 2000, F.P. Index No. 0010025.

Recommendation - That the above units be accepted on condition that all uses, configurations, arrangements, functions, locations and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standards RS 17-11 and 17-12. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72, the UL listing and the UL standard. Model DH200RP duct detector shall be used with listed and approved control panels with which the compatibility has been determined by a UL test report.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance October 30, 2000

Examined By Mark J. [Signature]

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner

**MEA 390-00-E Vol. II
Report of Material and Equipment Acceptance Division**

**Manufacturer - System Sensor, A Division of Pittway, 3825 Ohio Avenue,
St. Charles, IL. 60174**

Trade Name(s) – System Sensor and Fire Control Instruments Inc.

Product – Fire Alarm Equipment - Duct Detectors.

Pertinent Code Section(s) – RS 17-3, RS 4-6 (886-89-BCR).

Test(s) - UL 268A.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S911, Project 90NK1703, Volume 26, Section 1, issued August 20, 1990, revised August 24, 2000 and UL letter dated October 4, 2000 and ML File No. S1913 Issued December 2, 1986 and revised September 26, 2000.

Description – Duct Detectors are multiple listed as follows:

Basic Supplier System Sensor, A Division of Pittway Corp	Multiple Listee Fire Control Instruments Inc.
DH200P (MEA 128-00-E)	ADS-P
DH200RP (MEA 390-00-E)	ADS-RP

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention had no objections letter dated January 24, 2001, F.P. Index No. 0101014 under MEA 128-00-E for equivalent model no. DH200P and the Bureau of Fire Prevention had no objections letter dated October 18, 2000, F.P. Index No. 0010025 under MEA 390-00-E for equivalent model no. DH200RP.

Recommendation - That the above units be accepted on condition that all uses, configurations, arrangements, functions, locations and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standards RS 17-11 and 17-12. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72, the UL listing and the UL standard.

The above duct detectors shall be used with listed and approved control panels with which the compatibility has been determined by a UL test report.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance April 16, 2001

Examined By Mark J. [Signature]